



SCK TESTING LABS

(A UNIT OF SCK CERTIFICATIONS PVT. LTD.)

NABL ACCREDITED LAB: TC-14744 (22/10/2028)

C-5, Second Floor, Sector -10, Noida, Uttar Pradesh - 201301

info@scktestinglabs.com www.scktestinglabs.com +91-9310237402

CIN: U74999DL2020PTC368862 GSTN: 09ABECS3090C1ZG



TC-14744

TEST REPORT

Test Report Number	RSCKTL/WT/2608/2506	ULR Number	TC147442600000960F
Job Order Number	SCKTL/WT/2608/2506	Customer Ref. Number	-
Date of Issue	29.08.2026	Sample Received On	25.08.2026
Discipline Name	Chemical & Biological Testing	Product Group	Water (Drinking water)
NAME & ADDRESS OF CUSTOMER Issued to: M/s, Heritage Xperiential Learning School, I – 5, Sector – 128, Noida, U.P. 201304		SAMPLE DETAILS	
		Sample Description	: One Sample of Drinking Water (RO Water)
		Sampling Done By	: SCKTL lab Representative (Mr.Madhav)
		Date of Sampling	: 25.08.2026
		Sampling Location	: A – Block Ground Floor
		Sampling Protocol	: IS:17614 (Part-1,3 & 25)
		Sample Packing	: Plastic Bottle + Sterilized Glass Water
		Sample Marking	: THXLS/RO WATER/01
		Sample Quantity	: 2L + 500 ml
		Analysis Done On	: 25.08.2026 to 28.08.2026

TEST RESULTS (WATER SAMPLE ANALYSIS)						
S. No	Parameters	Unit	Results	Max Requirement as per (IS-10500-2012) Amnd 4		Test Method
				Acceptable	Permissible	
1.	Color	Hazen	< 5	5 max	15 max	IS: 3025(Pt-04/CI-4)2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS: 3025(Part-05)
3	Turbidity	NTU	<0.5	1 NTU max	5 max	IS: 3025(Part-10)2023
4	pH Value @ 25 °C	-	6.70	6.5-8.5	No Relaxation	IS: 3025(Part-11)2022
5	Total Hardness (as CaCO ₃)	mg/l	14.1	200 max	600 max	IS 3025 (Pt21)2009 RA2023
6	Total Alkalinity as CaCO ₃	mg/l	16.2	200 max	600 max	IS: 3025 (Part-23)2023
7	Total Dissolved Solids	mg/l	110	500 max	2000 max	IS: 3025 (Part-16)2023
8	Chlorides (as Cl)	mg/l	35	250 max	1000 max	IS: 3025(Pt 32)1988
9	Calcium (as Ca)	mg/l	3.2	75 max	200 max	IS: 3025(Part-40)
10	Magnesium (as Mg)	mg/l	1.5	30 max	100 max	IS: 3025(Part-46):2023
11	Fluoride (as F)	mg/l	<0.1	1.0 max	1.5 max	APHA 24 th Ed., 4500 F(D)
12	Sulphate (as SO ₄)	mg/l	6.2	200 max	400 max	IS: 3025 (P-24/Sec1) 2022
13	Nitrate (as NO ₃)	mg/l	2.2	45 max	No Relaxation	IS: 3025(P-34, Sec1) 2023
14	Electrical conductivity @ 25 °C	µmhos/cm	170	-	-	IS: 3025(Part-14):2013
Bacteriological Quality of Drinking Water						
15	Total Coliform	Per 100 ml	Absent	Shall not be detectable in any 100ml sample		IS:15185:2016
16	E. Coli	Per 100 ml	Absent	Shall not be detectable in any 100ml sample		IS:15185:2016

Note: 1. Sample Will be retained for 7 days for Biological & 15 days for chemical from the date of issue of test report. 2. The results given above are related only to the sample tested or sampled and tested thereafter 3. This report cannot be used as techno-legal evidence in court of law without the written approval of the lab. 4. Report shall not be reproduced, except in full, without prior written approval of the laboratory

Bahul Kumar
(Dy. Manager)
Reviewed by

Reeta Singh
(Senior Microbiologist)
Authorized Signatory



Vijay Vishwakarma
(Technical Manager)
Authorized Signatory

Format No. SCKTL/7.8F-W01 Issue No. 02 Issue Date 17.11.2023 Rev No. 01 Rev Date 07.08.2024

End of Report

Page No. 1 of 1



SCK TESTING LABS

(A UNIT OF SCK CERTIFICATIONS PVT. LTD.)

NABL ACCREDITED LAB: TC-14744 (22/10/2028)

C-5, Second Floor, Sector -10, Noida, Uttar Pradesh - 201301

info@scktestinglabs.com www.scktestinglabs.com +91-9310237402

CIN: U74999DL2020PTC368862 GSTN: 09ABEC53090C1ZG



TC-14744

TEST REPORT


Test Report Number	RSCKTL/WT/2608/2507	ULR Number	TC1474426000000961F
Job Order Number	SCKTL/WT/2608/2507	Customer Ref. Number	-
Date of Issue	29.08.2026	Sample Received On	25.08.2026
Discipline Name	Chemical & Biological Testing	Product Group	Water (Drinking water)
NAME & ADDRESS OF CUSTOMER		SAMPLE DETAILS	
Issued to: M/s, Heritage Xperiential Learning School, I - 5, Sector - 128, Noida, U.P. 201304		Sample Description	: One Sample of Drinking Water (RO Water)
		Sampling Done By	: SCKTL lab Representative (Mr.Madhav)
		Date of Sampling	: 25.08.2026
		Sampling Location	: C - Block Ground Floor
		Sampling Protocol	: IS:17614 (Part-1,3 & 25)
		Sample Packing	: Plastic Bottle + Sterilized Glass Water
		Sample Marking	: THXLS/RO WATER/002
		Sample Quantity	: 2L + 500 ml
		Analysis Done On	: 25.08.2026 to 28.08.2026

TEST RESULTS (WATER SAMPLE ANALYSIS)						
S. No	Parameters	Unit	Results	Max Requirement as per (IS-10500-2012) Amnd 4		Test Method
				Acceptable	Permissible	
1.	Color	Hazen	< 5	5 max	15 max	IS: 3025(Pt-04/CI-4)2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS: 3025(Part-05)
3	Turbidity	NTU	<0.5	1 NTU max	5 max	IS: 3025(Part-10)2023
4	pH Value @ 25 °C	-	6.68	6.5-8.5	No Relaxation	IS: 3025(Part-11)2022
5	Total Hardness (as CaCO ₃)	mg/l	14	200 max	600 max	IS 3025 (Pt21)2009 RA2023
6	Total Alkalinity as CaCO ₃	mg/l	18.2	200 max	600 max	IS: 3025 (Part-23)2023
7	Total Dissolved Solids	mg/l	108	500 max	2000 max	IS: 3025 (Part-16)2023
8	Chlorides (as Cl)	mg/l	36	250 max	1000 max	IS: 3025(Pt 32)1988
9	Calcium (as Ca)	mg/l	3.2	75 max	200 max	IS: 3025(Part-40)
10	Magnesium (as Mg)	mg/l	1.5	30 max	100 max	IS: 3025(Part-46):2023
11	Fluoride (as F)	mg/l	<0.1	1.0 max	1.5 max	APHA 24 th Ed., 4500 F(D)
12	Sulphate (as SO ₄)	mg/l	4.8	200 max	400 max	IS: 3025 (P-24/Sec1) 2022
13	Nitrate (as NO ₃)	mg/l	1.4	45 max	No Relaxation	IS: 3025(P-34, Sec1) 2023
14	Electrical conductivity @ 25 °C	µmhos/cm	160	-	-	IS: 3025(Part-14):2013
Bacteriological Quality of Drinking Water						
15	Total Coliform	Per100 ml	Absent	Shall not be detectable in any 100ml sample		IS:15185:2016
16	E. Coli	Per 100 ml	Absent	Shall not be detectable in any 100ml sample		IS:15185:2016

Note: 1. Sample Will be retained for 7 days for Biological & 15 days for chemical from the date of issue of test report. 2. The results given above are related only to the sample tested or sampled and tested thereafter 3. This report cannot be used as techno-legal evidence in court of law without the written approval of the lab. 4. Report shall not be reproduced, except in full, without prior written approval of the laboratory.

Rahul Kumar
(Dy. Manager)
Reviewed by

Reeta Singh
(Senior Microbiologist)
Authorized Signatory



Vijay Vishwakarma
(Technical Manager)
Authorized Signatory

Format No. SCKTL/7.8F-W01 Issue No. 02 Issue Date 17.11.2023 Rev No. 01 Rev Date 07.08.2024

End of Report

Page No. 1 of 1



SCK TESTING LABS

(A UNIT OF SCK CERTIFICATIONS PVT. LTD.)

NABL ACCREDITED LAB: TC-14744 (22/10/2028)

C-5, Second Floor, Sector -10, Noida, Uttar Pradesh - 201301

info@scktestinglabs.com www.scktestinglabs.com +91-9310237402

CIN: U74999DL2020PTC368862

GSTN: 09ABECS3090C1ZG



TC-14744

TEST REPORT


Test Report Number	NRSCKTL/FS/2608/2508	ULR Number	TC1474426000000970F
Job Order Number	RSCKTL/FS/2608/2508	Customer Ref. Number	-
Date of Issue	31.08.2026	Sample Received On	25.08.2026
Discipline Name	Biological Testing	Product Group	Environment & Pollution (Swab)
NAME & ADDRESS OF CUSTOMER		SAMPLE DETAILS	
Issued to: M/s, Heritage Xperiential Learning School, I – 5, Sector – 128, Noida, U.P. 201304		Sample Description	: One Sample of "Hand Swab"
		Sampling Done By	: SCK Testing Labs (representative Mr. Madhav)
		Date of Sampling	: 25.08.2026
		Sampling Location	: CAFETERIA, B- BLOCK
		Sampling Protocol	: SCK/STP/MIC/001
		Sample Packing	: Sterilized Swab Stick
		Sample Marking	: Mrs. Chandra Bhatt
		Sample Quantity	: 02
		Analysis Done On	: 25.08.2026 to 30.08.2026

TEST RESULTS

TEST RESULTS						
S. No	Parameters	Unit	Results (Right Hand)	Results (Left Hand)	Requirement as per WHO	Test Method
1.	Total Plate Count	cfu/swab	64	72	500	IS:5402(P-1):2021
2.	Yeast and Mould	cfu/swab	28	22	500	IS:5403:1999
3.	Coliform Count	cfu/swab	Nil	Nil	-	IS :5401 part -1:2012
4.	S.aureus	per/swab	Absent	Absent	-	IS:5887 Part-2:1976

Note: 1. Sample Will be retained for 7 days for Biological & 15 days for chemical from the date of issue of test report. 2. The results given above are related only to the sample tested or sampled and tested thereafter 3. This report cannot be used as techno-legal evidence in court of law without the written approval of the lab. 4. Report shall not be reproduced, except in full, without prior written approval of the laboratory.

Akansha Tomar
(Microbiologist)
Reviewed by



Reeta Singh
(Senior Microbiologist)
Authorized Signatory

Format No. SCKTL/7.8F-W01 Issue No. 02 Issue Date 17.11.2023 Rev No. 01 Rev Date 07.08.2024

End of Report